

DEKRA Testing and Certification GmbH • PO Box 102748 • 44727 Bochum, Germany

Micro Motion Inc.  
Mr James Warren  
7070 Winchester Circle  
Boulder, Co. 80301  
UNITED STATES OF AMERICA

**DEKRA Testing and Certification GmbH**

Location Bochum  
Explosion Protection Electrotechnology  
Dinnendahlstraße 9  
44809 Bochum, Germany  
Telephone +49.234.3696-0  
Telefax +49.234.3696-111

Contact Dipl.-Ing. Klaus Bendieck  
Phone direct +49.234.3696-328  
Fax direct +49.234.3696-301  
E-mail klaus.bendieck@dekra.com  
Date 2023-10-09

Our reference BVS-Ben/Mu  
Your sign  
Your reference

**Micro Motion Field Mount Transmitter, Series 4700 in combination with  
Micro Motion Coriolis Flow and Density Meters model type CMFS, CMF, (F, H, R, CNG050),  
HPC or T**

Dear Mr. Warren,

We herewith confirm that, during the period required to update the sensor certificates, the Micro Motion Field Mount Transmitter, Series 4700, as approved under Sira 19ATEX2008X (Zone 1), Sira 19ATEX3009X (Zone 2), and IECEx SIR 19.0007X (Zone 1 and 2) can be connected to the following Micro Motion Coriolis Flow and Density Meters.

**Zone 1**


Sensor	ATEX/IECEx Certificates
Sensor Type CMFS	BVS 09 ATEX E 018 X / IECEx BVS 09.0011X
Sensor Type CMF	BVS 15 ATEX E 045 X / IECEx BVS 15.0035X
SensorType F, H, R, CNG050	BVS 18 ATEX E 096 X / IECEx BVS 06.0005X
Sensor Type HPC	BVS 16 ATEX E 133 X / IECEx BVS 16.0083X
Sensor Type T	DMT 01 ATEX E 083 X / IECEx BVS 13.0054X

**Zone 2**

Sensor	ATEX/IECEx Certificates
Sensor Type CMFS	BVS 14 ATEX E 180 X / IECEx BVS 14.0122X
Sensor Type CMF	BVS 13 ATEX E 081 X / IECEx BVS 13.0091X
SensorType F, H, R, CNG050	BVS 13 ATEX E 083 X / IECEx BVS 13.0093X
Sensor Type HPC	BVS 16 ATEX E 121X / IECEx BVS 16.0087X
Sensor Type T	BVS 06 ATEX E 093 X / IECEx BVS 06.0011X

Yours sincerely  
DEKRA Testing and Certification GmbH

  
\_\_\_\_\_  
Dr. Michael Wittler

  
\_\_\_\_\_  
Klaus Bendieck