

## CERTIFICATE

Registered No.:

CER-IND 1102822101004005

Date of expired 7th March 2026

Assessment report No. CR-IND 1102822101004005 Date of issue 8th March 2023

This is to certify that the following company comply with the relevant requirements of mentioned safety standards:

Applicant:

Emerson Automation Solutions Final Control (Sichuan) Co., Ltd.

Address: 1128 Kong Gang 4th Road, Southwest Airport

Economic Development Zone, Chengdu City, Sichuan

Province, P.R. China

Product:

Bettis RPX-Series, Rack and Pinion Pneumatic Actuators

**Double Acting (DA)** 

Spring Return (SR)

Scope:

IEC 61508: 2010, (Part 1~7)

SIL3 (with HFT≥1)

Open or Close on demand

Remark:

 $\mathsf{PFD}_{\mathsf{avg}}$  and Architecture Constraints must be verified for each

application.

The unit must be properly integrated into a Safety instrumented

function per the requirements in SIL Safety ManualZHO

effery Fan

Name and Signature

Approval and signed after the surveillance first annually audit:

Issued at Shanghai Place, Stamp

TUV NORD

Approval and signed after the second annually surveillance audit:

TÜV NORD (Hangzhou) Co., Ltd

Room 409, Building 1, No.9 Jiu Huan Road, Shang Cheng District, Hangzhou, Zhejiang Province, China, 310019 SH Branch: No.1, Lane 288 Kangning Road Jingan District, Shanghai 200443, China

Tel: +86-21-33196200 Fax:+86-21-33196334

www.tuv-nord.com/cn





## **APPENDIX**

of certificate No.: CER-IND1102822101004005

Page 1 of 1

Date of expired 7<sup>th</sup> March 2026 Assessment report No. CR-IND 1102822101004005 Date of issue 8<sup>th</sup> March 2022 Revision: 0

Product:	Bettis RPX-Series, Rack and Pinion Pneumatic Actuators	
Specific of product:	Туре:	Type A Element
	Route	2 <sub>H</sub>
	DC: ( Diagnostic coverage )	0%
	λd Dangerous Failure Rate	9.91E-09 (Double Acting) 1.81E-08 (Spring Return)
	λdu (Dangerous Undetected Failure Rate)	9.91E-09 (Double Acting) 1.81E-08 (Spring Return)
	λdd (Dangerous Detected Failure Rate)	0.00E+00 (Double Acting) 0.00E+00 (Spring Return)
	λs (Safety Failure Rate)	2.82E-09 (Double Acting) 4.59E-09 (Spring Return)
	Proof test intervals:	8784 Hours (12 Months)
	MTTR: ( Mean Time to Repair )	24 Hours
	β: ( Fraction of common cause )	10%
	PFD <sub>avg</sub> @ 1oo1: ( Probability of Failure)	4.38E-05 (Double Acting) 8.00E-05 (Spring Return)
	PFD <sub>avg</sub> @ 1oo2: ( Probability of Failure)	4.38E-06 (Double Acting) 8.01E-06 (Spring Return)

Approval and signed after the first annually surveillance audit:

Approval and signed after the second annually surveillance audit:

TÜV NORD (Hangzhou) Co., Ltd

Room 409, Building 1, No.9 Jiu Huan Road, Shang Cheng District, Hangzhou, Zhejiang Province, China, 310019 SH Branch: No.1, Lane 288 Kangning Road Jingan District, Shanghai 200443, China

Tel: +86-21-33196200 Fax:+86-21-33196334

www.tuv-nord.com/cn