

# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-CA-2323373-0  
**Report Reference** E25549-20230627  
**Date** 29-Jun-2023

**Issued to:** ASCO, L.P.  
160 Park Ave  
Florham Park, NJ 07932  
United States

**This is to certify that representative samples of** YTSX7 - Valves, Electric for Use in Hazardous Locations  
Certified for Canada  
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** CSA C22.2 No. 30, Edition 4, Issued 2020/04/01  
CSA C22.2 No. 25, Edition 4, Issue Date 07/2017 (R. 2022)  
CSA C22.2 No. 94.2:20, Edition 3, Issue Date 10/15/2020  
CSA C22.2 No. 139-19, Edition 5, Issue Date 12/2019

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

  
Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-CA-2323373-0  
**Report Reference** E25549-20230627  
**Date** 29-Jun-2023

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

<b>Model</b>	<b>Category Description</b>
Series 327, may be preceded by 8, G or J, followed by suffix C, followed by 1 or 3, followed by 0, 1, J or L, followed by 2, followed by F2, F3, F4, F8, FN, FS, FT, FU, TA, TB, TC, TD, TJ, TK, TL, TM, followed by 9YT, 92J, 92K, 92L, 9YU, 9MC, 9MD, or 9W2, followed by H0, H1, H3, H9, HD, HM, HN, HQ, HS, J2, J7, LU or NL for use in Class I, Division 1, Groups B, C and D; Class II, Division 1, Groups E, F and G Hazardous Locations. Provided with process seal, single seal type. Enclosure Type 4X, 6 and 6P.	Electrically Operated Valves for HazLoc

*Deborah Jennings-Conner*

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-US-2327162-0  
**Report Reference** E25549-20230627  
**Date** 29-Jun-2023

**Issued to:** ASCO, L.P.  
160 Park Ave  
Florham Park, NJ 07932  
United States

**This is to certify that representative samples of** YTSX - Valves, Electric for Use in Hazardous Locations  
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** UL 1203, Edition 5, Issued 2013/11/22, Revised 2022/04/05  
UL 50E, Edition 3, Issue Date 10/15/2020  
UL 122701, Edition 4, Revision Date 09/29/2022  
UL 429, Edition 7, Revised Date 2021/03/19

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

  
Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>





# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-US-2327162-0  
**Report Reference** E25549-20230627  
**Date** 29-Jun-2023

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

<b>Model</b>	<b>Category Description</b>
Series 327, may be preceded by 8, G or J, followed by suffix C, followed by 1 or 3, followed by 0, 1, J or L, followed by 2, followed by F2, F3, F4, F8, FN, FS, FT, FU, TA, TB, TC, TD, TJ, TK, TL, TM, followed by 9YT, 92J, 92K, 92L, 9YU, 9MC, 9MD, or 9W2, followed by H0, H1, H3, H9, HD, HM, HN, HQ, HS, J2, J7, LU or NL for use in Class I, Division 1, Groups B, C and D; Class II, Division 1, Groups E, F and G Hazardous Locations. Provided with process seal, single seal type. Enclosure Type 4X, 6 and 6P.	Electrically Operated Valves for HazLoc

*Deborah Jennings-Conner*  
Deborah Jennings-Conner, VP Regulatory Services



UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>