

1 **EU - TYPE EXAMINATION CERTIFICATE**

2 **Equipment or Protective System Intended for use in Potentially Explosive Atmospheres
Directive 2014/34/EU**

3 EU - Type Examination Certificate Number: **Baseefa16ATEX0121 – Issue 1**

4 Product: **K1 Series Switchbox**

5 Manufacturer: **Topworx Incorporated**

6 Address: **3300 Fern Valley Road, Louisville, Kentucky, 40213, USA**

7 This re-issued certificate extends EU Type Examination Certificate No. **Baseefa16ATEX0121** to apply to product designed and constructed in accordance with the specification set out in the Schedule of the said certificate but having any variations specified in the Schedule attached to this certificate and the documents therein referred to.

8 SGS Fimko Oy, Notified Body number 0598, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

8.1 The original certificate was issued by SGS Baseefa Ltd (UK Notified Body 1180). It, and any supplements previously issued by SGS Baseefa Ltd have been transferred to the supervision of SGS Fimko Oy (EU Notified Body 0598). The original certificate number is retained.

The examination and test results are recorded in confidential Report No. **See Certificate History**

9 Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN IEC 60079-0: 2018 EN 60079-1: 2014 EN 60079-31: 2014

except in respect of those requirements listed at item 18 of the Schedule.

10 If the sign “X” is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.

11 This EU - TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.

12 The marking of the product shall include the following :

**⊕ II 2 GD Ex db IIC T* Gb
Ex tb IIIC T***°C Db IP66/67/68
Ta (see schedule)**

**⊕ II 2 GD Ex db IIC T6/T4 Gb
Ex tb IIIC T85°C / T135°C Db IP**
Ta (see schedule)**

SGS Fimko Oy Customer Reference No. **2191**

Project File No. **21/0331**

This document is issued by the Company subject to their General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> . Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company’s findings at the time of their intervention only and within the limits of Client’s instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company’s sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Fimko Oy

Takomotie 8
FI-00380 Helsinki, Finland
Telephone +358 (0)9 696 361
e-mail sgs.fimko@sgs.com
web site www.sgs.fi

Business ID 0978538-5 Member of the SGS Group (SGA SA)



Tuomas Hänninen
SGS Fimko Oy

13

Schedule

14

Certificate Number Baseefa16ATEX0121 – Issue 1

15 Description of Product

The Type K1 Series switchbox comprises an upper and base housing manufactured from aluminium alloy, or stainless steel. The two halves are secured by two M6 screws of minimum grade A2-70 stainless steel.

The enclosure may contain terminals, an electronics module, and cams attached to a shaft which passes through the base housing. The cams operate switches, proximity sensors or potentiometers. The upper housing is fitted with a shaft, driven from the cam shaft, to provide an external visual indication of shaft position. The combination of switches, sensors, proximity sensors or potentiometers etc are coded for temperature classification and maximum ambient temperature as listed. The maximum ratings are specified on the schedule drawings.

The base is provided with up to two threaded cable entries, and the position monitor is rated up to 275V 10A.

Cable entry holes are provided as specified on the certified drawings for the accommodation of flameproof cable entry devices, with or without the interposition of a flameproof thread adaptor. Unused entries are to be fitted with certified flameproof stopping plugs.

When used in an explosive dust atmosphere the cable entry devices shall maintain the ingress protection of the enclosure. The cable entry devices, thread adaptors and stopping plugs shall be suitable for the equipment, the cable and the conditions of use, and shall be certified as Equipment (not a Component).

For subtypes identified as EC4.x – T4/T135°C (Ta -60°C to +80°C)

For subtypes identified as EC4H.x – T4/T135°C (Ta -60°C to +120°C)

For subtypes identified as EC6.x – T6/T85°C (Ta -60°C to +40°C)

For subtypes identified as EC6H.x – T6/T85°C (Ta -60°C to +70°C)

16 Report Number

See Certificate History

17 Specific Conditions of Use

None

18 Essential Health and Safety Requirements

In addition to the Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9, the following are considered relevant to this product, and conformity is demonstrated in the report:

Clause	Subject
1.4.1	External effects
1.4.2	Aggressive substances, etc.

19 Drawings and Documents

New drawings submitted for this issue of certificate:

None

Current drawings which remain unaffected by this issue:

Number	Sheet	Issue	Date	Description
*C13843	1	1	19/09/16	Certification label – Topworx K1 Series Ex d IIC Switchbox
*C13830	1	1	23/09/16	Topworx K1 Series Ex db IIC
*C13830	2	1	23/09/16	Topworx K1 Series Ex db IIC Dual marking parameters
Baseefa11ATEX0010				Type 007-100 IIC Position Monitor

* The above drawings are common to Baseefa16ATEX0121 and IECEx BAS 16.0092.

20 Certificate History

Certificate No.	Date	Comments
Baseefa16ATEX0121	18 October 2016	The release of the prime certificate. The associated test and assessment against the requirements of EN60079-0: 2012 +A11: 2013, EN60079-1: 2014 and EN60079-31: 2014 is documented in Test Report No. GB/BAS/ExTR16.0223/00.
Baseefa16ATEX0121 Issue 1	6 September 2023	This issue of the certificate incorporates previously issued primary & supplementary certificates into one certificate and confirms that the current design meets the requirements of EN IEC 60079-0: 2018. The associated assessment is documented in Report GB/Bas/ExTR21.0096/00.
For drawings applicable to each issue, see original of that issue.		