

No.: 2021312315000498

**Applicant** Topworx Incorporated

3300 Fern Valley Road, Louisville, Kentucky 40213, United States of **Address** 

America

Topworx Incorporated Manufacturer

**Address** 3300 Fern Valley Road, Louisville, Kentucky 40213, United States of

**America** 

Topworx Incorporated **Production Factory** 

**Production Address** 3300 Fern Valley Road, Louisville, Kentucky 40213, United States of

**America** 

**Product** Go Switch with Connection Head

7\*\*\*5\*\*\*\*\*\*\* Model/Type

Ex db eb IIC T4/T6 Gb, Ex tb IIIC T130°C/T85°C Db Ex marking

GB/T3836.1-2021, GB/T3836.2-2021, GB/T3836.3-2021, Reference Standards

GB/T3836.31-2021

Type Test + Initial Factory Inspection + Post-Certification Surveillance Certification mode

The product(s) is verified and certified according to CNCA-C23-01: 2019 China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product and CNEX-C2301-2019 Guideline of China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product.

See Annex for the detailed product information (3 pages)

Initial issue date: 2021-10-29

Valid to: 2026-10-28 Issued date: 2023-03-20

The validity of this certificate is maintained through the regular supervision of the issuing authority during the validity period.

Where any discrepancy arises between the English translation and the original Chinese version,

the Chinese version shall prevail.

Director:





Nanyang Explosion Protected Electrical Apparatus Research Institute Co., Ltd.

PRODUCT CNAS C208-P

P.C.: 473008

http://www.ccc-cnex.com ccc.china-ex.com

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China Tel: 0377-63239734

Email: ccc@cn-ex.com



### (Annex)

**No.**: 2021312315000498

Page 1 of 3

#### Product information:

This certificate covers the following models:

Nomenclature for model

7	*	***************************************	((((((	5	*	*	**	*	*	*****
Series	1)	2)	3)	4)	5)	6)	7)	8)	9)	10)

1) Body style: 1 or 1M, 3 or 3M, 5 or 5M, 7, G or GM, I

1M: M12×1

3M, 5M, GM: M18×1

2) Contact arrangement: 1, 2

1: S.P.D.T

2: D.P.D.T

3) Sensing distance: 3, 4, 5, 6

3: 2.5mm

4: 1.8mm

5: 1.5mm

6: 1.0mm

4) Outlet position: 5

5) Enclosure material: 2 or 6

2: 303 S.S

6: 316 S.S

6) Certified Option: X, Y

X: Ex d e with Hermetic seal

Y: Exde

7) Termination type: JA, JS

JA: Junction Box (Aluminum)

JS: Junction Box (Stainless Steel)

8) Conduit Opening: P, M

P: 1/2" NPT

M: M20

9) Regional Cert

Issued date: 2023-03-20

Director:





Nanyang Explosion Protected Electrical Apparatus Research Institute Co., Ltd.



Email: ccc@cn-ex.com

P.C.: 473008



(Annex)

No.: 2021312315000498

Page 2 of 3

Blank: UL (North America), IECEx, ATEX

B: InMetro (Brazil)
K: KCs (Korea)
N: CCCEx (China)
P: PESO (India)

R: EAC (Eurasian Economic Union)

T: ITRI (China Taiwan)

10) Custom Build Indents

6 digits ( without relevance for explosion protection.)

Ratings: 1.2A at 24VAC, 0.5A at 125VAC, 4A at 120VAC, 3A at 120VAC,

3A at 24VDC, 1A at 24VDC

Ex marking: Ex db eb IIC T4/T6 Gb, Ex tb IIIC T130°C/T85°C Db

The corresponding relationship between ambient temperature and temperature class

is as follows:

Ambient temperature	Temperature class			
-40°C ≤ Ta ≤ +50°C	T6/T85°C			
-40°C ≤ Ta ≤ +100°C	T4/T130°C			

- Producers should organize production in accordance with the technical documents approved by the certification body.
- 2. Specific conditions of safety use:
  - Ingress protection: IP66.
  - The 70 Series Go Switch with Connection Head assembly shall be suitably earthed by its installation via the male thread of the Go Switch body.
  - Do not allow dust layers to build up on this product.
  - All terminal screws, used and unused, shall be fully tightened down by the end user.
  - No more than one single or multi-stranded lead shall be connected to the terminal unless multiple conductors have been joined in a suitable manner, e.g. two conductors into a single insulated bootlace ferrule, or any method indicated on the terminal certificate.

Issued date: 2023-03-20

Director:

磅九五



Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.





(Annex)

No.: 2021312315000498

Page 3 of 3

- All terminals, and accessories such as cross-connectors, shall be installed in accordance with the terminal manufacturer's instructions. Topworx Incorporated will supply the relevant terminal manufacturer's instructions with each assembly covered by this certificate.
- The maximum voltage and current shown on the rating label must not be exceeded.
- When connecting conductors of cross section below the maximum 2.5mm² allowed for the terminal then the maximum amps per pole must be reduced inline with the maximum amps permitted for a terminal equivalent to the conductor size fitted.
- See instruction for other information.
- 3. Certificate related report(s):
  - Type test report: CQST2106C172, CQST2106C172/01
  - Factory inspection report: CN2021Q010370
- 4. Certificate change information:

- 1st change on March 20, 2023: Updated the standards for certification.

Issued date: 2023-03-20

Director:

榜人弘



Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.



Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China Tel: 0377–63239734

Email: ccc@cn-ex.com

P.C.: 473008