



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 1611957 (LR 83777)

Master Contract: 179806

Project: 1875246

Date Issued: 2007/02/06

Issued to: Fisher Service Company
1612 S 17th Ave
Marshalltown, IA 50158
USA
Attention: Dennis Sickels

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by: Glenn Black

Authorized by: Patricia Pasemko, Operations Manager

PRODUCTS

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations -
Certified to US Standards

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Div. 2, Groups A, B, C, D; Enclosure Type 4:

Keypad Display, Model W40124, rated 10 to 30V dc, 1.2W max., temperature code T5, ambient range -20C to +70C.

Note: Device is for mounting in suitable panels or enclosures where the final assembly is subject to acceptance of CSA or the inspection authority having jurisdiction. To maintain Type 4 rating, device must be installed in a

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



CSA INTERNATIONAL

Certificate: 1611957 (LR 83777)

Master Contract: 179806

Project: 1875246

Date Issued: 2007/02/06

Certified Type 4 panel or enclosure in accordance with Fisher Instruction Form A6164.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures

CSA Std C22.2 No 142-M1987 - Process Control Equipment

CSA Std C22.2 No 213-M1987 - Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations

UL Std No 916, March 7, 2006 - Energy Management Equipment

UL Std. No 1604, Feb. 3, 2004 - Electrical Equipment for Use in Class I and Class II, Division 2 and Class III, Hazardous (Classified) Locations



CSA INTERNATIONAL

Supplement to Certificate of Compliance

Certificate: 1611957

Master Contract: 179806

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
1875246	2007/02/06	Revised Construction
1611957	2004/11/05	Original Certification