



Certificate of Compliance

Certificate: 1685886 (LR 44092)

Master Contract: 152450

Project: 70006628

Date Issued: February 12, 2015

Issued to: Micro Motion Incorporated

7070 Winchester Cir

Boulder, CO 80301

USA

Attention: Ray C. Stengl

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Ron Wachowicz

Issued by: Ron Wachowicz

PRODUCTS

CLASS 2258 83 - PROCESS CONTROL EQUIPMENT-Intrinsically Safe and Non-Incendive - Systems-For Hazardous Locations-Certified to U.S. Standards

CLASS 2258 03 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe and Non - Incendive Systems - For Hazardous Locations

IS: Class I, Division 1, Groups C and D; NI: Class I, Division 2, Groups A, B, C and D; DUST: Class II, Division 1 & 2, Groups E, F and G:

Model 800 Signal processing Device, Maximum input 17.3 Vdc, 0.484 A; Temperature Code T3A; Ambient -40°C to +60°C; Enclosure Type 4; Intrinsically Safe when connected as per Installation Instructions CSA-D-IS

Model 800C Remote Signal processing Device, Maximum input 17.3 Vdc, 0.484 A; Temperature Code T3A; Ambient -40°C to +60°C; Enclosure Type 4; Intrinsically Safe when connected as per Installation Instructions CSA-D-IS.



Certificate: 1685886 (LR 44092)

Master Contract: 152450

Project: 70006628

Date Issued: February 12, 2015

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 0-10 - General Requirements - Canadian Electrical Code Part II.

CSA Std C22.2 No. 0.4-M2004 - Bonding and Grounding of Electrical Equipment (Protective Grounding)

CSA Std C22.2 No. 0.5-M1982 - Threaded Conduit Entries

CSA Std C22.2 No. 25-M1966 (R2009) - Enclosures for use in Class II Groups E, F and G Hazardous Locations

CSA Std C22.2 No. 94-M1991 (R2006) - Special Purpose Enclosures

CSA Std C22.2 No. 142-M1987 (R2009) - Process Control Equipment

CSA Std C22.2 No. 157-M1992 (R2012) - Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations

CSA Std C22.2 No. 213-M1987 (R2013) - Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations

UL 50, 11th Edition - Enclosures for Electrical Equipment

UL 508, 17th Edition - Industrial Control Equipment.

UL 913, 7th Edition - Intrinsically Safe Apparatus and Associated Apparatus for use in Class I, II, III, Division 1, Hazardous (Classified) Locations.

UL 1203, 5th Edition - Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations

ANSI/ISA 12.12.01:2012 - Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations