



SITIIAS
Worldwide Access

EXPLOSION PROTECTION CERTIFICATE OF CONFORMITY

Cert No. GYJ22.3187X

Manufacturer	Tescom (Address: 12616 Industrial Boulevard, Elk River, Minnesota 55330, USA)
Product	Electro-Pneumatic Controller
Model	ER5050 <i>a b</i> -1 -<i>c</i>
Ex marking	Ex db IIB+H₂ T5 Gb, Ex tb IIIC T100°C Db
Product standard	/
Drawing number	ERAA10010

The product was found to comply with the following standard(s):
GB/T 3836.1-2021, GB/T 3836.2-2021, GB/T 3836.31-2021


Valid until: 2027.10.14

Remarks

1. Conditions for safe use are specified in the attachment(s) to this certificate.
2. Symbol "X" placed after the certification number denotes specific conditions of use, which are specified in the attachment(s) to this certificate.
3. Model designation is specified in the attachment(s) to this certificate.



Approval


Shanghai Inspection and Testing Institute of
Instruments and Automation Systems Co., Ltd.
National Supervision and Inspection Center for
Explosion Protection and Safety of Instrumentation
Date of issue 2022.10.15

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.

103 Cao Bao Road
Shanghai 200233, China

<http://www.nepsi.org.cn>
Email: info@nepsi.org.cn

Tel: +86 21 64368180
Fax: +86 21 64844580