



Certificate of Compliance

Certificate: 80102917

Master Contract: 152450

Project: 80102917

Date Issued: 2021-10-27

Issued To: Micro Motion Incorporated
7070 Winchester Cir
Boulder, Colorado, 80301
United States

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.

Issued by: *Doug Bramwell*
Doug Bramwell



PRODUCTS

CLASS 2252 06 - PROCESS CONTROL EQUIPMENT

CLASS 2252 86 - PROCESS CONTROL EQUIPMENT (Certified to U.S. Standards)

Magnetic Flowtube, Model 8721 rated 40 Vdc max, 0.5Adc max, 60°C ambient, Type 4, 4X.

Notes:

1. The above model is permanently connected, Equipment Class I (protective earth is provided when transmitter is connected), Pollution Degree 2.
2. Mode of operation: Continuous
3. Environmental Conditions: -15°C to 60°C, 2000 m max, 80% to temperatures up to 31 °C decreasing linearly to 50% rH at 40 °C, maximum process temperature: 160°C;



Certificate: 80102917
Project: 80102917

Master Contract: 152450
Date Issued: 2021-10-27

Note: The above model is a component for use with Process Control Equipment where the suitability is to be determined.

Products may be marked with any of the following Trademarks and/or Tradenames: "Rosemount" or "Micro Motion"

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No. 61010-1-12, UPD1: 2015, UPD2: 2016, AMD1: 2018 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements

CSA Standard C22.2 NO. 94.2-15 - Enclosures for Electrical Equipment, Non-Environmental Considerations

UL 61010-1, 3rd edition (2012), AMD:2018 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements

UL Standard 50E, 2nd Ed. - Enclosures for Electrical Equipment, Non-Environmental Considerations

CONDITIONS OF ACCEPTABILITY

- (1) Equipment is not to be used with flammable liquids.
- (2) Equipment has only been tested for electrical safety. No evaluation of functional safety and performance characteristics has been conducted.



Supplement to Certificate of Compliance

Certificate: 80102917

Master Contract: 152450

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80102917	2021-10-27	Model 8721 Magnetic Flowtube. Transfer from Master Contract 264512, Report 70139711 (Emerson - Rosemount-Micro Motion Inc.) to Master Contract 152450 (Micro Motion Incorporated).