

CERTIFICATE OF COMPLIANCE

Certificate Number 20181221-E125326
Report Reference E125326-20021106
Issue Date 2018-DECEMBER-21

Issued to: Topworx Inc
3300 Fern Valley Rd Louisville KY 40213-3528

**This certificate confirms that
representative samples of**

TELEMETERING EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS

See the addendum page for Models/Product

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

See the addendum page

Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20181221-E125326
Report Reference E125326-20021106
Issue Date 2018-DECEMBER-21

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Standard(s) for Safety:

UL 913 - Intrinsically Safe Apparatus And Associated Apparatus for Use in Class I, II, And III, Division 1, Hazardous (Classified) Locations
UL 1203 - Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations
ISA 12.12.01 - Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
CAN/CSA C22.2 No. 157-92 - Intrinsically Safe and Nonincendive Equipment for Use in Hazardous Locations
CAN/CSA C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations
CAN/CSA C22.2 No. 213-M1987 - Non-Incendive Electrical Equipment For Use In Class I, Division 2 Hazardous Locations, Edition 1

Models/Product:

Discrete Valve Controller, Model DXS/DXP/DXR –FF, FL, or FP followed by 0, followed by G, R, F, Y, T, 4, B1, B3, B5, B7 or B9, followed by S, N, 1 or 2, followed by E, 4, M, 5, 8, 6, 1, 9, 7, 3, A or B, followed by S, followed by Blank, P, R, or U, followed by Blank, A, S, 6, B or R, followed by any number or letter, followed by any number or letter. Intrinsically Safe for use in Class I, Division 1, Groups A, B, C and D Hazardous Locations when connected in accordance with Control Drawing CERT-ES-03467-1.

Discrete Valve Controller, Model DXS/DXP/DXR –FF, FL or FP followed by 2, followed by G, R, F, Y, T, 4, B1, B3, B5, B7 or B9, followed by S, N, 1 or 2, followed by E, 4, M, 5, 8, 6, 1, 9, 7, 3, A or B, followed by S, followed by Blank, P, R, or U, followed by Blank, A, S, 6, B or R, followed by any number or letter, followed by any number or letter. Non-incendive for use in Class I, Division 2, Groups A, B, C and D Hazardous Locations when connected in accordance with Control Drawing CERT-ES-03468-1.

Discrete Valve Controller, Model DXS/DXP-FF, FL or FP followed by 1, followed by G, R, F, Y, T, 4, B1, B3, B5, B7 or B9, followed by S, N, 1 or 2, followed by E, 4, M, 5, 8, 6, 1, 9, or 7, followed by S, E, B, or V, followed by Blank, P, R, or U, followed by Blank, A, S, 6, B or R, followed by any number or letter, followed by any number or letter. Explosion-Proof for use in Class I, Division 1, Groups C and D Hazardous Locations.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

